



VERSORGUNGSSPANNUNG

VAC	VDC	
Phase (L)	+ VDC	1
Neutral (N)	- VDC	2
Erde (PE)	Erde (PE)	3

(Siehe 4.1 Details Betriebsanleitung)

AUSGANGSSIGNAL

RELAIS ALARM MINIMALE dP (K1)

RELAIS ALARM MAXIMALE dP (K2)

4÷20mA signal am ausgang
 SIGNAL ACTIVE POWERED

DIFFERENZ
 DRUCK

Max dP
 10 kPa

- P2 (filtro lado limpio)

+ P1 (dP filtro lado sucio)