



VERSORGUNGSSPANNUNG

VAC	VDC	
Phase (L)	+ VDC	1
Neutral (N)	- VDC	2
Erde (PE)	Erde (PE)	3

(Siehe 4.1 Details Betriebsanleitung)

**AUSGANGSSIGNAL**

ALARM Min / Max dP

ALARM EMISSIONEN

DIFFERENZ DRUCK

Max dP  
10 kPa

- P2 (filtro lado limpio)  
+ P1 (dP filtro lado sucio)

18 VDC  
4 ÷ 20 mA

SHIELDED CABLE



**CONNECTION TRIBO CHECK**

