



CONNECT INPUT SIGNALS TO CONTACTS WITHOUT VOLTAGE

SUPPLY VOLTAGE

VAC	VDC	
Phase (L)	+ VDC	1
Neutral (N)	- VDC	2
Earth (PE)	Earth (PE)	3

(See 4.1 Technical features)

OUTPUT SIGNALS

CUMULATIVE ALARM RELAY (K1)
(See 7.1 Indications in alarms)

INPUT SIGNALS

ADDITIONAL CYCLES FROM CONTACT
Contact close = cycle enabled
LINK CLAMPS IF NOT USED WITH INPUTS FROM EXTERNAL CONTACT ENABLED
(See 2.2 Code D1ab1)

ON / OFF CLEANING FROM EXTERNAL CONTACT
Contact close = cycle enabled
LINK CLAMPS IF NOT USED WITH INPUTS FROM EXTERNAL CONTACT ENABLED
(See 2.2 Code D6)

