



**SUPPLY VOLTAGE**

| VAC         | VDC        |   |
|-------------|------------|---|
| Phase (L)   | + VDC      | 1 |
| Neutral (N) | - VDC      | 2 |
| Earth (PE)  | Earth (PE) | 3 |

(See 4.1 Technical features)

**OUTPUT SIGNALS**

RELAY SUPPLY VOLTAGE ON (K1)  
Contact close with voltage On

CUMULATIVE ALARM RELAY (K2)  
(See 7.1 Indications in alarms)

**INPUT SIGNALS**

VENTILATOR SWITCH  
Contact close = ventilator ON  
LINK CLAMPS IF NOT USED WITH INPUTS  
FROM EXTERNAL CONTACT ENABLED  
(See 2.2 Code D1a)

ON / OFF CLEANING FROM EXTERNAL CONTACT (D6a)  
ON/OFF PRESSURE SWITCH (C6a)  
Contact close = cycle enabled  
LINK CLAMPS IF NOT USED WITH INPUTS  
FROM EXTERNAL CONTACT ENABLED  
(See 2.2 Code C6a/D6a)

BUS LINE 1

YELLOW / GREEN  
BROWN  
BLUE  
3x0,75

